

SDWIS/State Water Sample Schedule Report
WEST VALLEY DEMONSTRATION PROJ PWS ID: NY0417557

Due 2023 Contaminant (Group) Sample Location/Frequency	Last Compliance Results	Sample Requirements
---	-------------------------	---------------------

Coliform, Total (TCR)

<input checked="" type="checkbox"/> Location: Distribution System Frequency: 1 Sample Quarterly Samples to be collected by CCHD staff. A positive total coliform (TC+) sample requires notifying the health department and collecting repeat distribution system samples within 24 hours. Unless otherwise directed by the health department, source (or raw) water before any treatment, from all active wells, must also be sampled within 24 hours.	1 Sample must be collected every quarter between 1/1 and 12/31.
---	--

Nitrate

<input checked="" type="checkbox"/> Location: TREATMENT BUILDING ID: TP-001 Frequency: 1 Sample Yearly Sample Point: TREATMENT BUILDING Sample Point No.: EP-003 Sample Point Type: EP-Entry Point Sample to be collected by CCHD staff.	Samples last collected: 4/13/2022	Sample must be collected by 12/31/2023
---	--------------------------------------	---

Part 5-1.52 Table 9B - Principal Organic Chemicals

<input checked="" type="checkbox"/> Location: TREATMENT BUILDING ID: TP-001 Frequency: 1 Sample Yearly Sample Point: TREATMENT BUILDING Sample Point No.: EP-003 Sample Point Type: EP-Entry Point	Samples last collected: 10/2/2022	Next sample must be collected between 10/1 and 12/31 within a single year by 12/31/2023
--	--------------------------------------	--

Part 5-1.52 Table 9C - PFOA, PFOS and 1,4-Dioxane

<input checked="" type="checkbox"/> Location: WELL #1 ID: WL-001 Frequency: 1 Sample Yearly Sample Point: WELL #1 Sample Point No.: RW-002 Sample Point Type: RW-Raw Water Source	Samples last collected: 8/15/2022	Next sample must be collected between 10/1 and 12/31 within a single year by 12/31/2023
Must report results of all analytes included in EPA Method 533. This is due to a detection in 2022.		
<input checked="" type="checkbox"/> Location: WELL #2 ID: WL-002 Frequency: 1 Sample Yearly Sample Point: WELL #2 Sample Point No.: RW-003 Sample Point Type: RW-Raw Water Source	Samples last collected: 8/15/2022	Next sample must be collected between 10/1 and 12/31 within a single year by 12/31/2023

Asbestos

<input type="checkbox"/> Location: DISTRIBUTION SYSTEM ID: DS-001 Frequency: 1 Sample Every 9 years Waiver system; must submit waiver documentation	Next sample must be collected by 12/31/2030
---	--

Part 5-1.42 and 5-1.47 - Lead and Copper

<input type="checkbox"/> Location: DISTRIBUTION SYSTEM ID: DS-001 Frequency: 5 Samples Every 3 years	5 Samples Collected on or Before: 9/12/2021	Next 5 samples must be collected between 6/1 and 9/30 within a single year by 9/30/2024
Samples must be collected from the sites listed on the Lead and Copper Sample Site Plan. Any change in locations must be approved by the CCHD before sampling.		

Part 5-1.52 Table 8B - Primary Inorganic Chemicals

<input type="checkbox"/> Location: TREATMENT BUILDING ID: TP-001 Frequency: 1 Sample Every 3 years Sample Point: TREATMENT BUILDING Sample Point No.: EP-003 Sample Point Type: EP-Entry Point	Samples last collected: 3/8/2018	Next sample must be collected by 12/31/2024
--	-------------------------------------	--

SDWIS/State Water Sample Schedule Report
WEST VALLEY DEMONSTRATION PROJ PWS ID: NY0417557

Due 2023 Contaminant (Group)/ Sample Location/Frequency	Last Compliance Results	Sample Requirements
--	-------------------------	---------------------

Part 5-1.52 Table 9A - Disinfection Byproducts/Stage 2

<input type="checkbox"/> Location: DISTRIBUTION SYSTEM ID: DS-001 Frequency: 1 Sample Every 3 years Sample Point: KTCHENETTE SINK W/IN THE RHWF (WNDKRH) Sample Point No.: LRAA1 Sample Point Type: MR-Maximum Residence Time Samples to be collected in the 2nd week of August.	Samples last collected: 8/24/2021	Next sample must be collected between 8/1 and 8/31 within a single year by 8/31/2024
---	--------------------------------------	---

Part 5-1.52 Table 9C - Synthetic Organic Chemicals

<input type="checkbox"/> Location: TREATMENT BUILDING ID: TP-001 Frequency: 1 Sample Every 3 years Sample Point: TREATMENT BUILDING Sample Point No.: EP-003 Sample Point Type: EP-Entry Point	Samples last collected: 12/20/2021	Next sample must be collected by 12/31/2024
--	---------------------------------------	--